

If the valve is installed during welding, weld in quarters using 125 F interpass temperature. Mid-position valve if possible. Follow Section G (Reduced Heat Input / Cooling Methods) of W91 / 191 Appendix A.