

If the valve is installed during welding, weld in halves using 125 F interpass temperature. Mid-position valve if possible. Follow Section G (Reduced Heat Input / Cooling Methods) of W91 / 191 Appendix A **or W93 Appendix A, as applicable. For mechanized welding, see Appendix B.**