

Coded Note Number: **W1420**

Revision: **C001**

Date: **September 2, 2017**

Title: **ELECTRICAL CABLE/WIRE THAT MIGHT HAVE PVC COATING**

This revision history is provided for convenience and does not alleviate the supplier's responsibility with understanding and complying with the full coded note.

Change from Revision A – Editorial change to reformat to current standard.

Bolded font indicates changed/added content.

[Text deleted] inserted in the document indicates the removal of content.

All cable furnished on this order must meet all requirements of the cited specification. Purchaser has recently received cable with PVC components which exude excessive plasticizer material in service. Cable furnished under this order must not exude, ooze, or drip.

Cable furnished on this order is subject to be tested by the purchaser after receipt to verify performance tests delineated in the procurement specification to be performed by the manufacturer. Failure of the cable furnished to pass such tests will be cause for rejection and return to the supplier.