

Coded Note Number: **Y1490**

Revision: **C001**

Date: **September 16, 2017**

Title: **440 VOLTS COMMERCIAL EQUIPMENT**

**This revision history is provided for convenience and does not alleviate the supplier's responsibility with understanding and complying with the full coded note.**

**Change from Revision A – Editorial change to reformat to current standard.**

**Bolded font indicates changed/added content.**

**[*Text deleted*] inserted in the document indicates the removal of content.**

Equipment furnished shall be suitable for operation on 440 volt, 60 hertz, 3 phase A.C. power supply.